

No: 1951 (20)2021/NK/PMPM

Office of the Nirmithi Kendra,
B Block, 4th Floor, Civil Station,
Kudappanakunnu, Thiruvananthapuram43.
Pmnirmithi01@gmail.com,0471-2732929
25/08/2021

INVITATION OF TENDER

District Nirmithi Kendra invites Competitive tender from authorized Firms/Experienced Individual in the form attached herewith for **Fire extinguishing system at TSCCC Building Thiruvananthapuram.**

S.No.	PARTICULARS	QTY	UNIT
1	Supply, filling and storage of Novec 1230 extinguishing agent in a seamless cylinder as per NFPA standards . The system shall utilise 42 bar pressure technology. Make : Honeywell/Siemens/Kidde or Equivalent	500	kg
2	Supply and installation of Manual abort Switch with flip cover or shall be protected against unwanted activation Make: Ravel/System sensor/ GST or Equivalent.	2	nos
3	Supply and installation of Manual Release Switch with flip cover or shall be protected against unwanted activation Make: Ravel/System sensor/ GST or Equivalent.	2	nos
4	Supply and installation of Nozzles. Nozzle size and type shall be decided as per manufacturer calculation Make : Honeywell/Siemens/Kidde or Equivalent	20	nos
5	Supply and installation of microprocessor controlled 2 Zone Gas Release Panel. Panel shall have minimum 1 nos agent release circuit and feature to prevent accidental release. Panel shall have builtin battery charger and shall include 2 nos 12V7AH battery. Panel shall be complied with CE Make: Ravel/System sensor/ GST or Equivalent.	2	nos
6	Supply and installation of seamless 120 Ltrs. Cylinder with Valve and all fittings required for the NFPA standard installation	4	nos
7	Supply and installation of seamless 100 Ltrs. Cylinder with Valve and all fittings required for the NFPA standard installation	1	nos
8	Supply and installation of M.S. ASTM A 106 Gr. B. Sch. 40 Seamless pipe network for extinguishing	1	nos

	agent flow with all fittings, supports as per OEM design plan and finished with fire red paint followed by one coat of primer, in server room and main operator room Make : Jindal/TATA/ equivalent		
		Total	

2) Bid Price

- a) Tender shall be for the full quantity as described above. Corrections if any shall be made by crossing out re-writing with initial and date.
- b) The rate should be all inclusive of taxes, levies, transports etc. Usual deduction of taxes will be made from the gross amount of bill.
- c) The rate quoted by the bidder shall be fixed for the duration of the tender and shall not be subject to adjustment on any account.
- d) The price should be quoted in Indian rupees only.

3) Each bidder shall submit only one tender.

4) Validity of tender

Tender shall remain valid for a period not less than 45 days after the dead line date specified for submission

5) Evaluation of tender

The tenderer will evaluate and compare the tender determined to be substantially responsive ie which

- a) Are properly signed
- b) Confirm to the terms and conditions and specification.

6) Award of Tender

- a) The work will award to the tenderer whose tender has been determined to be substantially responsive and who has offered the lowest evaluated quotation price
- b) The tenderer whose bid is accepted will be notified of the award of the contract by the purchaser prior to expiration of the quotation validity period. The terms of the accepted offer shall be incorporated in the purchase order.

7) The amount will be released after verification of the material in physical ,quality and

receipt of invoice in this office according to the availability of funds. Individual or authorized dealers/agents are only eligible.

8) Tenderer are requested to provide your offer latest by 12 hours on **04.09.2021** and the quotation will be opened at **04.09.2021**.

9) Cost of Tender form : Nil

10) Earnest Money Deposit : Nil

We look forward to receiving your tender and thank for your interest in this work.


PROJECT MANAGER
NIRMITHI KENDRA
THIRUVANANTHAPURAM

Copy to : Website & notice board

Tender Format

S.No.	PARTICULARS	QTY	UNIT	Rate	Amount
1	Supply, filling and storage of Novec 1230 extinguishing agent in a seamless cylinder as per NFPA standards . The system shall utilise 42 bar pressure technology. Make : Honeywell/Siemens/Kidde or Equivalent	500	kg		
2	Supply and installation of Manual abort Switch with flip cover or shall be protected against unwanted activation Make: Ravel/System sensor/ GST or Equivalent.	2	nos		
3	Supply and installation of Manual Release Switch with flip cover or shall be protected against unwanted activation Make: Ravel/System sensor/ GST or Equivalent.	2	nos		
4	Supply and installation of Nozzles. Nozzle size and type shall be decided as per	20	nos		

	manufacturer calculation Make : Honeywell/Siemens/Kidde or Equivalent				
5	Supply and installation of microprocessor controlled 2 Zone Gas Release Panel. Panel shall have minimum 1 nos agent release circuit and feature to prevent accidental release. Panel shall have builtin battery charger and shall include 2 nos 12V7AH battery. Panel shall be complied with CE Make: Ravel/System sensor/ GST or Equivalent.	2	nos		
6	Supply and installation of seamless 120 Ltrs. Cylinder with Valve and all fittings required for the NFPA standard installation	4	nos		
7	Supply and installation of seamless 100 Ltrs. Cylinder with Valve and all fittings required for the NFPA standard installation	1	nos		
8	Supply and installation of M.S. ASTM A 106 Gr. B. Sch. 40 Seamless pipe network for extinguishing agent flow with all fittings, supports as per OEM design plan and finished with fire red paint followed by one coat of primer, in server room and main operator room Make : Jindal/TATA/ equivalent	1	nos		
	Total				

Gross Total Cost: - Rs.....

(In words) We agree to supply the above goods in accordance with the technical Specification for a total price of Rs.....(amount in figure).....(amount in words) with in the period specified in the invitation for quotation.

Signature of Tenderer