

No:1951/2021/NK/TVPM

Office of the Nirmithi Kendra,  
B Block, 4th Floor, Civil Station,  
Kudappanakunnu, Thiruvananthapuram 43.  
Pmnirmithi01@gmail.com, 0471-2732929  
09.02.2022

**Quotation notice for Fire Resistant Door Work (3)**

District Nirmithi Kendra invites Competitive quotation from authorized Firms/Experienced Individual in the form attached herewith for supply and fixing fire resistant door works at TSCCC Building Thiruvananthapuram.

S.No.	PARTICULARS	QTY	UNIT
1	Providing and fixing fire resistant door frame of section 50 x 60 mm on horizontal side & 35 x 60 mm on vertical sides having built in rebate made out of 1.6 mm thick GI sheet (Zinc coating not less than 120gm/m <sup>2</sup> ) suitable for mounting 120min Fire Rated Glazed Door Shutters. The frame shall be filled with Mineral wool Insulation having density min 96Kg/m <sup>2</sup> . The frame will have a provision of G.I. Anchor fasteners 14 nos (5 each on vertical style & 4 on horizontal style of size M10 x 80) suitable for fixing in the opening along with Factory made Template for SS Ball Bearing Hinges of Size 100x89x3mm for fixing of fire rated glazed shutter. The frame shall be finished with a approved fire resistant primer or Powder coating of not less than 30 micron in desired shade as per the directions of Engineer - in- charge. (Cost of SS ball bearing hinges is excluded)	12	mtr
2	Providing and fixing 60 mm thick glazed fire resistant door shutters of 120 min Fire Rating confirming to IS:3614 (Part II) or EN1634-1:1999, tested and certified as per laboratory approved by Engineer-in-charge, with suitable mounting on door frame, consisting of vertical styles, top rail & side rail 60 mm x 60 mm wide and bottom rail of 110 mm x 60 mm made out of 1.6mm thick G.I. sheet (zinc coating not less than 120gm/m <sup>2</sup> ) duly filled mineral wool insulation having density min 96 kg/m <sup>3</sup> and fixing with necessary stainless steel ball bearing hinges of size 100x89x3mm of approved make, including applying a coat of approved fire resistant primer or powder coating not less than 30 micron etc all complete as per direction of Engineer-in-charge (panelling to be paid for separately)	5.76	m <sup>2</sup>

2) Bid Price

- a) Quotationer shall be for the full quantity as described above. Corrections if any shall be made by crossing out re-writing with initial and date.
- b) The rate should be all inclusive of taxes, levies, transports etc. Usual deduction of taxes will be made from the gross amount of bill.
- c) The rate quoted by the bidder shall be fixed for the duration of the quotation and shall not be subject to adjustment on any account.
- d) The price should be quoted in Indian rupees only.
- 3) Each bidder shall submit only one tender.

4) Validity of quotation

Quotation shall remain valid for a period not less than 45 days after the dead line date specified for submission

5) Evaluation of quotation

The quotationer will evaluate and compare the tender determined to be substantially responsive ie which

- a) Are properly signed
- b) Confirm to the terms and conditions and specification.

6) Award of Quotation

- a) The work will award to the quotationer whose quotation has been determined to be substantially responsive and who has offered the lowest evaluated quotation price
- b) The quotationer whose bid is accepted will be notified of the award of the contract by the purchaser prior to expiration of the quotation validity period. The terms of the accepted offer shall be incorporated in the purchase order.
- 7) The amount will be released after verification of the material in physical, quality and receipt of invoice in this office according to the availability of funds. Individual or authorized dealers/agents are only eligible.
- 8) Quotationer are requested to provide your offer latest by 12 hours on **18.02.2021** and the quotation will be opened at **18.02.2021**.

We look forward to receiving your quotation and thank for your interest in this work.

  
Project Manager

### Format of Quotation

S.No.	PARTICULARS	QTY	UNIT
1	<p>Providing and fixing fire resistant door frame of section 50 x 60 mm on horizontal side &amp; 35 x 60 mm on vertical sides having built in rebate made out of 1.6 mm thick GI sheet ( Zinc coating not less than 120gm/m<sup>2</sup>) suitable for mounting 120min Fire Rated Glazed Door Shutters. The frame shall be filled with Mineral wool Insulation having density min 96Kg/m<sup>2</sup> . The frame will have a provision off.I. Anchor fastners 14 nos ( 5 each on vertical style &amp; 4 on horizontal style of size M10 x 80 ) suitable for fixing in the opening along with Factory made Template for SS Ball Bearing Hinges of Size 100x89x3mm for fixing of fire rated glazed shutter . The frame shall be finished with a approved fire resistant primer or Powder coating of not less than 30 micron in desired shade as per the directions of Engineer - in- charge . (Cost of SS ball bearing hinges is excluded)</p>	12	mtr
2	<p>Providing and fixing 60 mm thick glazed fire resistant door shutters of 120 min Fire Rating conforming to IS:3614 (Part II) or EN1634-1:1999, tested and certified as per laboratory approved by Engineer-in-charge, with suitable mounting on door frame, consisting of vertical styles, top rail &amp; side rail 60 mm x 60 mm wide and bottom rail of 110 mm x 60 mm made out of 1.6mm thick G.I. sheet (zinc coating not less than 120gm/m<sup>2</sup>) duly filled with mineral wool insulation having density min 96 kg/m<sup>3</sup> and fixing with necessary stainless steel ball bearing hinges of size 100x89x3mm of approved make, including applying a coat of approved fire resistant primer or powder coating not less than 30 micron etc all complete as per direction of Engineer-in-charge (panelling to be paid for separately)</p>	5.76	m <sup>2</sup>

Gross Total Cost: - Rs.....

(In words) We agree to supply the above goods in accordance with the technical Specification for a total price of Rs.....(amount in figure).....(amount in words) with in the period specified in the invitation for quotation.

**Signature of Quotationer**